



601 N. Moapa Valley Boulevard * Post Office Box 257
Logandale, Nevada * 89021
Telephone (702) 397-6893 * Facsimile (702) 397-6894

To: Chairman Ken Staton & MVWD Board of Directors
From: Joseph Davis, General Manager
Date: January 12, 2018
Subject: Arrow Canyon #1

Background

Layne has supplied staff an estimate for the repair of Arrow Canyon #1 of \$34,567.35. The bowl assembly needs to be replaced with 316 stainless steel impellers, 416 stainless steel collets and 316 stainless steel bolting. The installation of 5 foot column pipe and bearings will allow the district to flow the pump and the lower speeds when needed.

With the urgency of needing reliable water resources, staff took the liberty to authorize the ordering of parts for the necessary repair.

Suggested Motion

Move to authorize the repairs of the Arrow Canyon #1 pumping equipment by Layne for a price not to exceed \$34,567.35