



601 N. Moapa Valley Boulevard \* Post Office Box 257  
Logandale, Nevada \* 89021  
Telephone (702) 397-6893 \* Facsimile (702) 397-6894

---

To: Chairman Randy Tobler, & MVWD Board of Directors  
From: Lon Dalley, Assistant General Manager  
Date: March 30, 2022  
Subject: Arrow Canyon #2 Well - Pull Pump/Column, Inspect Pump/Motor, Video Casing

### **Background**

Arrow Canyon Well #2 has a decent vibration to the motor/pump. We asked Layne Granite Company to look at the well for an opinion for correction, he was here the 22<sup>nd</sup> of March and recommends the pump/motor be pulled and inspected and correct any repairs needed. He believes that the spider bearings around the shaft are bad. This well was pulled and inspected in 2017 when the pump and the motor were refurbished. The estimated cost of pulling, inspecting, and videoing is **\$38,700.00**. They are booked and won't be able to get to us till mid-May. Due to MVWD needing all water sources available at any given time, staff recommends moving forward with the work.

### **Suggested Motion**

Move to approve the acceptance of Quote #CPM22011 from Layne Granite Company in the amount of **\$38,700.00** to Pull, Inspect and Video Well #2.