

Water Quality Report 2024

The Moapa Valley Water District is very pleased to provide you with the 2024 “Quality Water” Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide a safe and dependable supply of drinking water. We are pleased to report that our drinking water is safe and exceeds federal requirements. This report is provided to you to further explain our water quality and what it means.

YOUR WATER

The Muddy River and Lake Mead provide none of your drinking water. In fact, no surface water of any sort is delivered to your tap. The District’s spring collection systems at the Baldwin and the Jones Spring, in addition to the MX6 Well and the Arrow Canyon Well 1 & 2 provide an average of 2,441,271.64 gallons per day to our customers. Flowing through over 200 miles of pipeline in the District’s distribution system, the water from these groundwater sources arrives at your home having been disinfected using chlorine. Because our water supply is protected within the ground water aquifer, it does not require the level of treatment associated with surface water sources. We treat your water to remove several contaminants and we add disinfectant to protect you against microbial contaminants. The Safe Drinking Water Act (SDWA) requires states to develop a Source Water Assessment (SWA) for each public water supply that treats and distributes raw source water in order to identify potential contamination sources. The state has completed an assessment of our source water. For results of the source water assessment, please contact us. (702-397-6893)

TAP VS. BOTTLED

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline at 1-800-426-4791.

VIOLATIONS AND EXCEEDANCES

The Moapa Valley Water District had no violations with the Safe Drinking Water Act standards during the 2024 calendar year.

WHAT DO WE TEST FOR?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before it is treated are microbial contaminants, inorganic contaminants, pesticides and herbicides, radioactive contaminants, and organic chemical contaminants.

Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides may come from a variety of sources, such as agricultural and residential uses.

Radioactive contaminants are naturally occurring.

Organic chemical contaminants, including synthetic and volatile organic chemicals, are byproducts of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff, and septic systems.

HEALTH INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

LEAD

Your water meets EPA's standard for Lead, but if present at elevated levels, this contaminant can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Moapa Valley Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

VANDALISM

Vandalism affects everyone. We encouraged anyone who sees graffiti, gunshots holes, suspicious activity, etc at or around MVWD’s lines or facilities to call the company's 24-hour emergency number at 702-397-6893 or the Metropolitan Police Department. We also ask anyone who sees damaged waterlines, facilities or equipment to immediately report it to the same number. The District appreciates any help it gets from customers and the general public in stopping these senseless acts.

The Federal Safe Drinking Water Act (SDWA) was amended in 1996 and requires states to develop and implement source water assessment programs (SWAP) to analyze existing and potential threats to the quality of public drinking water throughout the state. A summary of a system’s susceptibility to potential sources of contamination was initially provided by the State of Nevada to the water system in 2004. This summary was included in the water system’s 2004 Consumer Confidence Report. Additional or updated information the water system may have regarding significant sources of contamination in the source water area may also be available. A copy of the SWAP summary and additional or updated information may be available through your water system by contacting Joseph Davis at 702-397-6893. Information pertaining to the initial findings of the source water assessment is also available for viewing at the Bureau of Safe Drinking Water (BSDW) Carson City office between the hours of 8:00 am and 5:00 pm, Monday through Friday. It is suggested that an appointment be made if you are interested in viewing this information. The office is located at 901 South Stewart Street, Suite 4001, Carson City, Nevada, 89701, telephone number (775) 687-9520.

The table below represents routine water analysis conducted annually in order to further the Districts effort to provide the most current, meaningful information to our customers.

WATER ANALYSIS

<u>Regulated Contaminants</u>	<u>Collection Date</u>	<u>Highest Value</u>	<u>Range</u>	<u>Unit</u>	<u>MCL</u>	<u>MCLG</u>	<u>Typical Source</u>
Arsenic	09/12/2024	8.9	6-9	ug/L	10	0.1	Erosion of natural deposits; runoff from orchards; Runoff from glass & electronics production wastes.
Fluoride	12/7/22	2.24	2.11-2.24	ppm	2	4	Erosion of natural deposits; Water additive which promotes strong teeth.
Antimony	9/13/24	0.0060	1-2	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Barium	9/13/24	0.046	0.046	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	9/13/24	0.010	0.010	ppb	0.10	100	Discharge from steel and pulp mills; Erosion of natural deposits.
Selenium	7/29/15	2	2	ppb	50	50	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Nitrate	12/05/2024	2.7	2.5-2.7	mg/L	10	10	Runoff from fertilizer use; leaching from septic tanks & sewage; erosion of natural deposits.
Nickel	9/13/24	0.030	0.002	mg/L	.01	.01	Occurs naturally in soils, groundwater, and surface water. Often used in electroplating, stainless steel and alloy products, mining, and refining.
<u>Secondary Contaminants</u>	<u>Collection Date</u>	<u>Highest Value</u>	<u>Range</u>	<u>Unit</u>	<u>SMCL</u>		<div><h3><u>QUESTIONS?</u></h3><p>If you have any questions about this report or concerning your water utility, please contact Joseph Davis at (702) 397-6893. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Board of Directors meetings. They are held on the second Thursday of each month at 4:00 p.m. in the Moapa Valley Water District office. Any variance from this will be noted on agendas posted at the Overton, Logandale, and Moapa Post Offices, Overton Library and the Moapa Valley Water District office. Agendas are also posted on our website www.moapawater.com.</p></div>
Aluminum	09/12/24	ND	0.050	ug/L	0.20 mg/L		
Chloride	12/6/22	62.7	62.7	mg/L	400		
Color	12/6/22	3.00	1.00	Color Units	15 color units		
Copper	09/12/24	0.010	1.00	ug/L	1000		
Magnesium	09/12/24	24.1	24.1	mg/L	150		
Iron	09/13/24	0.020	0.100	mg/L	0.60		
pH	12/6/22	7.78	7.78	pH	8.5		
Sodium	09/12/24	94.2	90.3-94.2	mg/L	200		
Sulfate	12/6/22	176	176	mg/L	500		
Total Dissolved Solids	09/13/24	549	543-549	mg/L	1000		
Zinc	09/13/24	0.030	0.030	ug/L	5000		
<u>Disinfection By-Products</u>	<u>Monitoring Period</u>	<u>RAA</u>	<u>Range</u>	<u>Unit</u>	<u>MCL</u>	<u>MCLG</u>	

TTHM	3/13/23	5.2	4.4-7.0	ug/L	80	0	By-product of drinking water chlorination
Total Haloacetic	5/15/24	ND	ND	Ug/L	60	0	
Lead and Copper	Date	90TH Percentile	Unit	AL	Sites over AL		<u>Typical Source</u>
Copper	9/23/22– 9/27/22	0.15	mg/L	< 1.0	0		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	9/23/22 – 9/27/22	0.0047	mg/L	< 0.015	0		Corrosion of household plumbing systems; erosion of natural deposits.
<u>Radionuclide's</u>	<u>Collection Date</u>	<u>Highest Value</u>	<u>Range</u>	<u>Unit</u>	<u>MCL</u>	<u>MCLG</u>	<u>Typical Source</u>
Combined Radium (-226 & -228)	12/11/19	2.72	1.21 - 2.72	pCi/L	5	0	Erosion of natural deposits
Combined Uranium	12/7/22	4.36	4.20 - 4.36	µg/L	30	0	Erosion of natural deposits

****Hardness averages 250 mg/L (17 grains per gallon)****

MCLG/Maximum contaminant level goal - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL/Maximum contaminant level - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best treatment technology. MCLs are set at very stringent levels.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow

ppm - parts per million

mg/L - milligrams per liter/the same as parts per million

ppb - parts per billion

ugl/L - micrograms per liter/the same as parts per billion

ND- not detected

ARSENIC

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems."

Lead Service Line Inventory

We have completed our Lead Service Line (LSL) inventory and confirmed that no lead service lines are present in our system. The full inventory report is available for review at the Moapa Valley Water District front office.



**WE'RE IN A DROUGHT.
OUR WATER IS TOO GOOD TO WASTE!**

Health Information About Water Quality

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).